



From: Bryan Dusza [mailto:bdusza@wtbco.com]
 Sent: Monday, April 21, 2014 2:12 PM
 To: Steve Halpern
 Cc: Dale Topper
 Subject: RE: Paint Branch Parkway - Relocated Calvert Road

Steve,

I talked to our structures department and they believe that removing a panel from the noise wall is feasible from a structural aspect. The wall is constructed with steel posts anchored in caisson foundations. The panel sections slide down into the post, therefore, removing a section should not interfere with the structural integrity of the adjacent sections. The bigger question may be how removing a panel section affects the acoustical benefit the wall is providing. If you have any more questions, please let us know.

Thanks,
 Bryan Dusza, P.E.
 The Wilson T. Ballard Company
 17 Gwynns Mill Court

By: College Park Engineering
 Date March 8, 2016
 Source: M-NCPPC GIS



City of College Park, Maryland
 Sound Barrier Removal and Bike Trail Extension



Sheet 1 of 1